

West Ada Water Testing Results - Final

Sites Built before 1986	Location of Water Sample	Test Result	Upper Limit Allowed	Replace Unit	Dated Tested
Achievment House	KITCHEN	0.001	0.015	NO	3/27/2019
	BATHROOM 1	0.0029	0.015	NO	3/27/2019
	BATHROOM 2	0.001	0.015	NO	3/27/2019
Barbra Morgan Elementary	RM 23S	0.004	0.015	NO	3/28/2019
	OFFICE DF	0.0039	0.015	NO	3/28/2019
	FACULTY RM	0.001	0.015	NO	3/28/2019
	BOYS RR S	0.001	0.015	NO	3/28/2019
	KITCHEN	0.0042	0.015	NO	3/28/2019
	RM 9 EAST	0.0057	0.015	NO	3/28/2019
	RM 8 WEST	0.0017	0.015	NO	3/28/2019
	RM 1 WEST	0.0011	0.015	NO	3/28/2019
	RM 22 SOUTH	0.007	0.015	NO	3/28/2019
	RM 10 EAST	0.0064	0.015	NO	3/28/2019
Centennial High	MAIN HALL DF	0.001	0.015	NO	3/27/2019
	KITCHEN MAIN WASH ST	0.001	0.015	NO	3/27/2019
	2ND FLR DF	0.001	0.015	NO	3/27/2019
	DF PATRIOT BLVD	0.0018	0.015	NO	3/27/2019
	POTTERY RM 2ND FLR	0.001	0.015	NO	3/27/2019
	G CHEER LRM GYM	0.001	0.015	NO	3/27/2019
	DF MINUTEMAN HALL	0.0014	0.015	NO	3/27/2019
	B VARSITY LRM DF	0.001	0.015	NO	3/27/2019
	CHEMISTRY RM 2ND FLR DF	0.0014	0.015	NO	3/27/2019
FACULTY LOUNGE	0.001	0.015	NO	3/27/2019	
Christine Donnell Elementary	GYM DF	0.001	0.015	NO	3/27/2019
	OFFICE HALL DF	0.001	0.015	NO	3/27/2019
	NURSES FAUCET	0.013	0.015	NO	3/27/2019
	6TH GRADE HALL DF	0.001	0.015	NO	3/27/2019
	RM 11 DF	0.012	0.015	NO	3/27/2019
	RM 10 DF	0.012	0.015	NO	3/27/2019
	RM 30 DF	0.013	0.015	NO	3/27/2019
	RM 31 DF	0.011	0.015	NO	3/27/2019
	RM 19 DF	0.016	0.015	YES	3/27/2019
RM 20 DF	0.011	0.015	NO	3/27/2019	

West Ada Water Testing Results - Final

Sites Built before 1986	Location of Water Sample	Test Result	Upper Limit Allowed	Replace Unit	Dated Tested
Eagle Elementary	KITCHEN	0.0011	0.015	NO	3/27/2019
	FEMALE RR BY F OFFICE	0.0046	0.015	NO	3/27/2019
	NURSES OFFICE	0.0039	0.015	NO	3/27/2019
	LIBRARY BLD CLOSET	0.0014	0.015	NO	3/27/2019
	COMPUTER LAB	0.0059	0.015	NO	3/27/2019
	KITCHEN TEACHER LOUNGE	0.0034	0.015	NO	3/27/2019
	RM 18	0.0073	0.015	NO	3/27/2019
	MUSIC ROOM	0.012	0.015	NO	3/27/2019
	MENS RR BY GYM	0.001	0.015	NO	3/27/2019
	CONFRENCE ROOM	0.0085	0.015	NO	3/27/2019
Eagle Hills Elementary	KITCHEN SINK	0.0033	0.015	NO	3/27/2019
	NURSES SINK	0.012	0.015	NO	3/27/2019
	MENS ROOM BY F OFFICE	0.0042	0.015	NO	3/27/2019
	LIBRARY SINK	0.0019	0.015	NO	3/27/2019
	TEACHERS LOUNGE SINK	0.0015	0.015	NO	3/27/2019
	WMNS RR ACROSS RM 13	0.012	0.015	NO	3/27/2019
	COMPUTER ROOM	0.0028	0.015	NO	3/27/2019
	ROOM 16	0.0018	0.015	NO	3/27/2019
	ROOM 4	0.0088	0.015	NO	3/27/2019
	ROOM 6	0.0062	0.015	NO	3/27/2019
Frontier Elementary	RM 1 DF	0.0058	0.015	NO	3/26/2019
	RM 6 DF	0.0057	0.015	NO	3/26/2019
	BLDG 2 BREAKROOM	0.0021	0.015	NO	3/26/2019
	RM 13 DF	0.019	0.015	YES	3/26/2019
	RM 17 DF	0.023	0.015	YES	3/26/2019
	KITCHEN PREP SINK	0.0062	0.015	NO	3/26/2019
	GYM DF TALL	0.0027	0.015	NO	3/26/2019
	RM 28 DF	0.0075	0.015	NO	3/26/2019
	RM 33 DF	0.032	0.015	YES	3/26/2019
BLDG 1 WORK ROOM	0.0082	0.015	NO	3/26/2019	
Grounds Building	MENS RR	0.0051	0.015	NO	3/26/2019
	WOMENS RR	0.011	0.015	NO	3/26/2019
	BREAKROOM SINK	0.0018	0.015	NO	3/26/2019
	HANDWASH SINK	0.0012	0.015	NO	3/26/2019
	DRINKING FOUNTAIN	0.0019	0.015	NO	3/26/2019

West Ada Water Testing Results - Final

Sites Built before 1986	Location of Water Sample	Test Result	Upper Limit Allowed	Replace Unit	Dated Tested
Joplin Elementary	GYM DF	0.001	0.015	NO	3/27/2019
	STAFF BRK ROOM	0.001	0.015	NO	3/27/2019
	RM 20 DF	0.001	0.015	NO	3/27/2019
	RM 14 DF	0.001	0.015	NO	3/27/2019
	RM 2 DF	0.0027	0.015	NO	3/27/2019
	MAIN BLD RR	0.001	0.015	NO	3/27/2019
	NURSES OFFICE	0.001	0.015	NO	3/27/2019
	UNI/SEX RR	0.002	0.015	NO	3/27/2019
	EYE WASH STATION CUST.	0.001	0.015	NO	3/27/2019
	KITCHEN SINK	0.0021	0.015	NO	3/27/2019
Lake Hazel Middle	500 HALL DF	0.0029	0.015	NO	3/27/2019
	600 HALL DF	0.001	0.015	NO	3/27/2019
	504 FAUCET BATHROOM	0.0032	0.015	NO	3/27/2019
	600 LAV FAUCET	0.019	0.015	YES	3/27/2019
	CAFATERIA DF	0.001	0.015	NO	3/27/2019
	300 HALL DF	0.001	0.015	NO	3/27/2019
	300 HALL DF	0.0013	0.015	NO	3/27/2019
	NURSES FAUCET	0.0018	0.015	NO	3/27/2019
	100 HALL DF	0.0012	0.015	NO	3/27/2019
	GYM DF	0.0012	0.015	NO	3/27/2019
Lake Hazel Elementary	RM 16 DF	0.0029	0.015	NO	3/26/2019
	RM 20 DF	0.0047	0.015	NO	3/26/2019
	RM 14 DF	0.0024	0.015	NO	3/26/2019
	NURSES FAUCET	0.013	0.015	NO	3/26/2019
	GYM DF	0.0013	0.015	NO	3/26/2019
	CUSTODIAN HALL DF	0.001	0.015	NO	3/26/2019
	FACULTY HALL DF	0.0013	0.015	NO	3/26/2019
	FACULTY FAUCET	0.0032	0.015	NO	3/26/2019
	RM 11 DF	0.011	0.015	NO	3/26/2019
RM 7 DF	0.014	0.015	NO	3/26/2019	

West Ada Water Testing Results - Final

Sites Built before 1986	Location of Water Sample	Test Result	Upper Limit Allowed	Replace Unit	Dated Tested
Lowell Scott Middle	BOYS RR COACHES SINK	0.001	0.015	NO	3/27/2019
	KITCHEN HANDWASH SINK	0.001	0.015	NO	3/27/2019
	8TH GRAD HALL DF	0.001	0.015	NO	3/27/2019
	DF MAIN HALL OFFICE	0.001	0.015	NO	3/27/2019
	FACULTY RM SINK	0.001	0.015	NO	3/27/2019
	6TH GRAD HALL BATHROOM	0.001	0.015	NO	3/27/2019
	FACULTY BATHROOM DF	0.009	0.015	NO	3/27/2019
	7TH GRADE HALL BATHROOM	0.002	0.015	NO	3/27/2019
	RM 35 FAR SINK	0.0058	0.015	NO	3/27/2019
	RM 27 1ST SINK	0.016	0.015	YES	3/27/2019
Mary McPherson Elementary	MENS RR BY GYM	0.001	0.015	NO	3/26/2019
	HANDICAPPED RR BY GYM	0.001	0.015	NO	3/26/2019
	RM 1	0.0058	0.015	NO	3/26/2019
	RM 2	0.001	0.015	NO	3/26/2019
	RM 3	0.0015	0.015	NO	3/26/2019
	RM 4	0.001	0.015	NO	3/26/2019
	RM 5	0.0012	0.015	NO	3/26/2019
	RM 6	0.0029	0.015	NO	3/26/2019
	RM 22	0.0051	0.015	NO	3/26/2019
	RM 23	0.0018	0.015	NO	3/26/2019
McMillan Elementary	RM 29 DF	0.0067	0.015	NO	3/27/2019
	DF OUTSIDE RM 25	0.015	0.015	YES	3/27/2019
	RM 22 DF	0.0022	0.015	NO	3/27/2019
	RM 16 DF	0.0022	0.015	NO	3/27/2019
	DF OUTSIDE THE CAFATERIA	0.0074	0.015	NO	3/27/2019
	CAFATERIA DF	0.012	0.015	NO	3/27/2019
	DF IN 3-4-5 HALL	0.001	0.015	NO	3/27/2019
	DF IN 7-3-4-5 HALL	0.001	0.015	NO	3/27/2019
	DF IN 3-4-5- HALL N.	0.0011	0.015	NO	3/27/2019
DF IN 2-3-4-5 HALL	0.001	0.015	NO	3/27/2019	

West Ada Water Testing Results - Final

Sites Built before 1986	Location of Water Sample	Test Result	Upper Limit Allowed	Replace Unit	Dated Tested
Meridian Elementary	OFFICE FOUNTAIN	0.0012	0.015	NO	3/26/2019
	NURSES FOUNTAIN	0.0043	0.015	NO	3/26/2019
	RM 1 FOUNTAIN	0.005	0.015	NO	3/26/2019
	KITCHEN HALL FOUNTAIN	0.0028	0.015	NO	3/26/2019
	BOILER / 19 FOUNTAIN	0.0036	0.015	NO	3/26/2019
	RM 12 ANNES FOUNTAIN	0.001	0.015	NO	3/26/2019
	RM 13 ANNEX FOUNTAIN	0.0012	0.015	NO	3/26/2019
	1ST GRADE HALL FOUNTAIN	0.001	0.015	NO	3/26/2019
	LIBRARY HALL FOUNTAIN	0.003	0.015	NO	3/26/2019
	ANNEX 7 FOUNTAIN	0.002	0.015	NO	3/26/2019
Meridian High	2nd Flr Gym DF	0.0015	0.015	NO	3/27/2019
	2ND Flr Gym H Sink	0.001	0.015	NO	3/27/2019
	B Gym Main LRm H Sink	0.001	0.015	NO	3/27/2019
	g Gym Main LRm H Sink	0.0053	0.015	NO	3/27/2019
	W ENT MAIN GYM DF	0.0011	0.015	NO	3/27/2019
	MAIN GYM TRAIN RM SINK	0.0035	0.015	NO	3/27/2019
	AG DF NEXT TO GYM	0.0046	0.015	NO	3/27/2019
	AG WOMENS BR SINK	0.0038	0.015	NO	3/27/2019
	FINE ARTS DF	0.001	0.015	NO	3/27/2019
	FINE ARTS MENS RR	0.001	0.015	NO	3/27/2019
Meridian Middle	BLDG 500 BOYS RR L. SINK	0.001	0.015	NO	3/26/2019
	BLDG 500 GIRLS RR R. SINK	0.005	0.015	NO	3/26/2019
	BLDG 300 HALL DF	0.0013	0.015	NO	3/26/2019
	BLDG 300 MENS STAFF RR SINK	0.001	0.015	NO	3/26/2019
	BLDG 600 BOYS RR DF	0.0046	0.015	NO	3/26/2019
	BLDG 600 GIRLS RR DF	0.0035	0.015	NO	3/26/2019
	BLDG 700 GIRLS RR R. SINK	0.0011	0.015	NO	3/26/2019
	BLDG 700 BOYS RR R. SINK	0.001	0.015	NO	3/26/2019
	BLDG 800 LOBBY DF	0.0087	0.015	NO	3/26/2019
	BLDG 800 GIRLS RR SINK	0.001	0.015	NO	3/26/2019

West Ada Water Testing Results - Final

Sites Built before 1986	Location of Water Sample	Test Result	Upper Limit Allowed	Replace Unit	Dated Tested
Silver Sage Elementary	FAUCET NORTH	0.0012	0.015	NO	3/27/2019
	FAUCET RM 113	0.0015	0.015	NO	3/27/2019
	DF RM 115	0.001	0.015	NO	3/27/2019
	FAUCET RM 104	0.001	0.015	NO	3/27/2019
	KITCHEN SINK	0.0021	0.015	NO	3/27/2019
	DF RM 105	0.001	0.015	NO	3/27/2019
	DF RM 102	0.001	0.015	NO	3/27/2019
	FAUCET RM 101	0.0027	0.015	NO	3/27/2019
Star Elementary	RM 1 DF	0.04	0.015	YES	3/26/2019
	RM 3 FAUCET	0.0036	0.015	NO	3/26/2019
	RM 5 DF	0.021	0.015	YES	3/26/2019
	BAYS RR FAUCET	0.0016	0.015	NO	3/26/2019
	GIRLS RR FAUCET	0.0029	0.015	NO	3/26/2019
	NURSES RR SINK FAUCET	0.001	0.015	NO	3/26/2019
	FACULTY WORK RM FAUCET	0.0014	0.015	NO	3/26/2019
	RM 14 DF	0.0018	0.015	NO	3/26/2019
	RM 16 FAUCET	0.0043	0.015	NO	3/26/2018
	RM 18 DF	0.0061	0.015	NO	3/26/2019
Summerwind Elementary	RM 6 DF	0.0015	0.015	NO	3/26/2019
	RM 12 DF	0.0023	0.015	NO	3/26/2019
	RM 15 DF	0.001	0.015	NO	3/26/2019
	RM 18 DF	0.0024	0.015	NO	3/26/2019
	NURSES OFFICE DF	0.0011	0.015	NO	3/26/2019
	DF # 1	0.001	0.015	NO	3/26/2019
	DF #3	0.0018	0.015	NO	3/26/2019
	DF #8	0.0019	0.015	NO	3/26/2019
	GYM DF	0.0013	0.015	NO	3/26/2019
	KITCHEN PREP SINK	0.004	0.015	NO	3/26/2019
Ustick Elementary	RM 13	0.0017	0.015	NO	3/27/2019
	RM 14	0.0011	0.015	NO	3/27/2019
	RM 19	0.012	0.015	NO	3/27/2019
	RM 20	0.018	0.015	YES	3/27/2019
	OFFICE NORTH	0.001	0.015	NO	3/27/2019
	OFFICE SOUTH	0.001	0.015	NO	3/27/2019
	BLDG 4 HALL DF	0.0016	0.015	NO	3/27/2019
	RM 23	0.001	0.015	NO	3/27/2019
	GYM NORTH DF	0.001	0.015	NO	3/27/2019
GYM SOUTH DF	0.0019	0.015	NO	3/27/2019	