



ADDENDUM

Date: February 23, 2018	Addendum #: Four
Project: Eagle Hills Elem Library Remodel	Project #: 17029.01
Address: 650 E Ranch Dr, Eagle, ID 83616	File Code: 2-b

BIDS DUE	
Time: 10:00 AM	
Date: March 9th, 2018	
Place: West Ada School District central offices.	
Address: 1303 E. Central Dr.	
City, State: Meridian, Idaho 83642	

To All Plan holders: Please notify everyone concerned as your sub-contractors and suppliers of the issuance and contents of this addendum prior to date of bid opening.

GENERAL

BID OPENING WILL BE POSTPONED TO MARCH 9th, 2018. 10:00 AM.

Bids due same location.

SPECIFICATIONS

Clarifications:

- An additional addendum will be coming out for inclusion of an add alternate to install new fire alarm voice/evac system.

Architectural:

- NONE

Mechanical:

- Division 21 – Fire suppression
 - Remove section in its entirety. Project does not include any fire sprinkler work.

DRAWINGS

- Sheet A2.0 Keynote 17. Provide new Knox box model 3200. Surface mount, black, no tamper switch.

APPROVALS: *Approvals are based on manufacturers only. Contractors are responsible for bidding on approved equipment equivalent in size and performance to that specified. Contractor is also responsible for all special electrical, mechanical, or other field adaptations required for equipment or items used other than that shown in the original project design. All mechanical and electrical equipment shall bear the UL label.*

- NONE

ATTACHMENT LIST:

NONE