

**ADDENDUM NO. 1**  
**May 2, 2019**

Project Number: WASD Bid # 912801- Chaparral Elementary Parking Lot Rehabilitation

Project Title: Rehabilitation of the Parking Lot at Chaparral Elementary School

Agency: West Ada School District, Meridian, ID

Engineer: KM Engineering, LLP

**Bid Opening: Monday, May 8, 2019 – 2:00 p.m.**

**Location: District Service Center, City of Meridian  
1303 East Central Drive, Meridian, Idaho 83642**

All information contained in this addendum is hereby made part of the contract documents pertaining to the above-mentioned project and shall be binding upon each Contractor submitting bids. Contractor shall be responsible to notify all sub-contractors and/or suppliers of the contents of this addendum.

**Additional Information:**

1. Clarification – All existing manholes and valve lids within the pavement area shall be adjusted to finish grade and have a concrete collar installed per the construction plan set requirements.

The contract documents for the project identified above are amended as follows:

1. Amend Section 02456 – Asphalt Paving to include a ½-inch Class I Asphalt meeting ISPWC Section 810 requirements.

END ADDENDUM ONE (1 Sheet Total)