



Addendum

DATE: May 8, 2020
TO: Bidders
FROM: Mike Carrithers, Purchasing Agent
RE: **Addendum 1** – Bid 013401 Auxiliary Gymnasium Floor at Centennial High School

ITEM 1: The following questions pertaining to this project have been asked:

Q: What is the current flooring made out of that you are wanting to install the new floating system over? Vinyl? Plastic? Urethane of some sort? We need to know as we have concerns about the athletic pads "sinking" into the existing flooring down the road, creating dead spots in the floor.

A: The existing flooring is a poured in place material over concrete.

Q: Since the existing floor is level with the doors, putting in the floating system will result in a height difference at doors and thresholds of near 2". Per ADA requirements this would mean a ramp extending close to 2' out from the floor to account for this. Was this realized?

A: Yes. This is addressed in section 3.3 INSTALLATION - FLOORING, paragraph H 12 of the Wood Flooring Specifications Manual. It states that the Contractor is to "Provide and install ADA compliant thresholds at all public access doorways. These thresholds are to be similar to what is currently installed at the gymnasium entries on the first floor."



West Ada

SCHOOL DISTRICT

Purchasing

1303 E. Central Drive, Meridian, ID 83642
p: (208) 855-4500 · f: (208) 350-5962

Q: Item 4.1.1. - I'm guessing we can ignore supplying a quote for a new dishwasher?

A: Correct, the reference to the dishwasher may be ignored.

Q: in the Bid packet there was an Additive Alternate. It asked to provide a quote for refinishing the main gymnasium. We can definitely do this. Would you happen to have the dimensions, game line tallies, and logo's specs so we can provide a detailed estimate?

A: In reviewing the original blueprints of the building, the distance from the East wall to the West wall is 100.0 feet. The measurement from the North wall to the South wall is 98' 8". However, these are the walls where the bleachers are located. The blueprints do not give closed dimensions on the bleachers. The bleachers have been replaced since the building was constructed. Estimate would be that in the closed position the bleachers are 6" deep. This results in a North South dimension of approximately 86' 8". Game lines and logos and other markings are to be recreated exactly as they are now.

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM (NO. 1) ON
THE BID SUBMITTAL FORM (ATTACHMENT 1)**