

Date: 6.12.2020	Addendum #: 04
Project: WASD - Meridian High School Auditorium – Stage Equipment Rebid, Bid # 017101	Project #: 18011.01
Address: 1900 W. Pine Ave, Meridian, Idaho 83642	File Code: 2-b

BIDS DUE	
Time: 3:00 pm	
Date: Thursday June 18, 2020	
Place: District Service Center	
Address: 1303 East Central Drive,	
City, State: Meridian, Idaho, 83642	

To All Planholders: Please notify everyone concerned as your sub-contractors and suppliers of the issuance and contents of this addendum prior to date of bid opening.

SPECIFICATIONS

Theater:

Reference Specification Section 116165 – Stage Rigging

Following clarifications are issued based on Request for Information during bid phase.

- All loads and batten lengths will be coordinated at submittals
- Aluminum will be acceptable as well as steel for the T-bar or J-bar counterweight system
- Loads for counterweights should be considered as follows:
 - 20lbs per foot for scenery and drapery lines
 - 40lbs per foot for electrics
 - 50lbs per foot for orchestra shells
- Threaded coupling of battens will not be accepted.
- Counterweight arbors will be coordinated at submittals.
- Specifications Section call for double purchase lines only. The drawings call for both single and double. Please disregard the specifications for this item and bid with both single and double purchase.
- Per ANSI E1.4-1, provide spreader plates per 2' of arbor length.

APPROVALS:

None

ATTACHMENT LIST:

None